

Submission to Planning Authority Notice

Council Planning Permit No.	DA0169/2017	Council notice date	28/06/2017
TasWater details			
TasWater Reference No.	TWDA 2017/01001-LCC	Date of response	05/10/2017
TasWater Contact	Anthony Cengia	Phone No.	(03) 6237 8243
Response issued to			
Council name	LAUNCESTON CITY COUNCIL		
Contact details	planning.admin@launceston.tas.gov.au		
Development details			
Address	40690 TASMAN HWY, WAVERLEY	Property ID (PID)	1482830
Description of development	Subdivision		
Schedule of drawings/documents			
	Prepared by	Drawing/document No.	Revision No.
	IPD Consulting	Typical Water layout	A
			Date of Issue
			02/10/2017
Conditions			
SUBMISSION TO PLANNING AUTHORITY NOTICE OF PLANNING APPLICATION REFERRAL			
Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater imposes the following conditions on the permit for this application:			
CONNECTIONS, METERING & BACKFLOW			
1. A suitably sized water supply with metered connection to each lot of the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.			
2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.			
3. Prior to commencing construction of the subdivision/use of the development, any water connection utilised for construction/the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater.			
ASSET CREATION & INFRASTRUCTURE WORKS			
4. Plans submitted with the application for Engineering Design Approval must, to the satisfaction of TasWater show, all existing, redundant and/or proposed property services and mains.			
5. Prior to applying for a Permit to Construct new TasWater infrastructure the developer must obtain from TasWater Engineering Design Approval for new TasWater infrastructure. The application for Engineering Design Approval must include engineering design plans prepared by a suitably qualified person showing the hydraulic servicing requirements for water to TasWater's satisfaction.			
6. Prior to works commencing, a Permit to Construct must be applied for and issued by TasWater. All infrastructure works must be inspected by TasWater and be to TasWater's satisfaction.			
7. In addition to any other conditions in this permit, all works must be constructed under the supervision of a suitably qualified person in accordance with TasWater's requirements.			
8. Prior to the issue of a Consent to Register a Legal Document all additions, extensions, alterations or			

upgrades to TasWater’s infrastructure required to service the development are to be constructed at the expense of the developer to the satisfaction of TasWater, with live connections performed by TasWater at the developer’s cost.

9. After testing to TasWater’s requirements, of newly created works, the developer must apply to TasWater for connection of these works to existing TasWater infrastructure, at the developer’s cost.
10. At practical completion of the water and sewerage works and prior to TasWater issuing a Consent to a Register Legal Document the developer must obtain a Certificate of Practical Completion from TasWater for the works that will be transferred to TasWater. To obtain a Certificate of Practical Completion:
 - a. Written confirmation from the supervising suitably qualified person certifying that the works have been constructed in accordance with the TasWater approved plans and specifications and that the appropriate level of workmanship has been achieved;
 - b. A request for a joint on-site inspection with TasWater’s authorised representative must be made;
 - c. Security for the twelve (12) month defects liability period to the value of 10% of the works must be lodged with TasWater. This security must be in the form of a bank guarantee;
 - d. As constructed drawings must be prepared by a suitably qualified person to TasWater’s satisfaction and forwarded to TasWater.
11. After the Certificate of Practical Completion has been issued, a 12 month defects liability period applies to this infrastructure. During this period all defects must be rectified at the developer’s cost and to the satisfaction of TasWater. A further 12 month defects liability period may be applied to defects after rectification. TasWater may, at its discretion, undertake rectification of any defects at the developer’s cost. Upon completion, of the defects liability period the developer must request TasWater to issue a “Certificate of Final Acceptance”. The newly constructed infrastructure will be transferred to TasWater upon issue of this certificate and TasWater will release any security held for the defects liability period.
12. The developer must take all precautions to protect existing TasWater infrastructure. Any damage caused to existing TasWater infrastructure during the construction period must be promptly reported to TasWater and repaired by TasWater at the developer’s cost.
13. Ground levels over the TasWater assets and/or easements must not be altered without the written approval of TasWater.

FINAL PLANS, EASEMENTS & ENDORSEMENTS

14. Prior to the Sealing of the Final Plan of Survey, a Consent to Register a Legal Document must be obtained from TasWater and the certificate must be submitted to the Council as evidence of compliance with these conditions when application for sealing is made.

DEVELOPMENT ASSESSMENT FEES

15. The applicant or landowner as the case may be, must pay a development assessment and Consent to Register a Legal Document fee to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date they are paid to TasWater, as follows:
 - a. \$479.09 for development assessment; and
 - b. \$226.94 for Consent to Register a Legal Document

The payment is required within 30 days of the issue of an invoice by TasWater.

16. In the event Council approves a staging plan, a Consent to Register a Legal Document fee for each

stage, must be paid commensurate with the number of Equivalent Tenements in each stage, as approved by Council.

Advice

General

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

Advice to Planning Authority (Council) and developer on fire coverage

TasWater cannot provide a supply of water for the purposes of firefighting to the full extent of all lots on the plan.

Declaration

The drawings/documents and conditions stated above constitute TasWater's Submission to Planning Authority Notice.

Authorised by



Jason Taylor

Development Assessment Manager

TasWater Contact Details

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au