



## Submission to Planning Authority Notice

Council Planning Permit No.	DA0123/2018	Council notice date	13/03/2018
<b>TasWater details</b>			
TasWater Reference No.	TWDA 2018/00350-LCC	Date of response	04/06/2018
TasWater Contact	Amanda Craig	Phone No.	03) 6345 6318
<b>Response issued to</b>			
Council name	LAUNCESTON CITY COUNCIL		
Contact details	planning.admin@launceston.tas.gov.au		
<b>Development details</b>			
Address	54 MULGRAVE ST , SOUTH LAUNCESTON	Property ID (PID)	6625175
Description of development	Subdivide and Adhere Land and Multiple dwellings		
<b>Schedule of drawings/documents</b>			
Prepared by	Drawing/document No.	Revision No.	Date of Issue
IPD Consulting	1692-03 General Arrangement - Plan	B	16/02/2018
<b>Conditions</b>			
<p>Pursuant to the <i>Water and Sewerage Industry Act 2008</i> (TAS) Section 56P(1) TasWater imposes the following conditions on the permit for this application:</p> <p><b>CONNECTIONS, METERING &amp; BACKFLOW</b></p> <ol style="list-style-type: none"> <li>1. A suitably sized water supply with metered connection/sewerage system and connection to each lot of the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.</li> <li>2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.</li> <li>3. Prior to commencing construction of the subdivision/use of the development, any water connection utilised for construction/the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater.</li> </ol> <p><b>ASSET CREATION &amp; INFRASTRUCTURE WORKS</b></p> <ol style="list-style-type: none"> <li>4. Plans submitted with the application for Certificate(s) for Certifiable Work (Building and/or Plumbing) / Engineering Design Approval must, to the satisfaction of TasWater show, all existing, redundant and/or proposed property services and mains.</li> <li>5. Prior to applying for a Permit to Construct new infrastructure the developer must obtain from TasWater Engineering Design Approval for new TasWater infrastructure. The application for Engineering Design Approval must include engineering design plans prepared by a suitably qualified person showing the hydraulic servicing requirements for sewerage to TasWater's satisfaction.</li> <li>6. Prior to works commencing, a Permit to Construct must be applied for and issued by TasWater. All infrastructure works must be inspected by TasWater and be to TasWater's satisfaction.</li> <li>7. In addition to any other conditions in this permit, all works must be constructed under the supervision of a suitably qualified person in accordance with TasWater's requirements.</li> </ol>			

8. Prior to the issue of a Consent to Register a Legal Document / Certificate of Water and sewerage Compliance (Building and/or (Plumbing) all additions, extensions, alterations or upgrades to TasWater's water and sewerage infrastructure required to service the development, generally as shown on the concept servicing plan "IPD Consulting, 1692-03 General Arrangement – Plan, rev B, dated 16/02/2018", are to be constructed at the expense of the developer to the satisfaction of TasWater, with live connections performed by TasWater.
9. After testing, to TasWater's requirements, of newly created works, the developer must apply to TasWater for connection of these works to existing TasWater infrastructure, at the developer's cost.
10. At practical completion of the water and sewerage works and prior to TasWater issuing a Consent to a Register Legal Document / applying to TasWater for a Certificate of Water and Sewerage Compliance (Building and/or Plumbing), the developer must obtain a Certificate of Practical Completion from TasWater for the works that will be transferred to TasWater. To obtain a Certificate of Practical Completion:
  - a. Written confirmation from the supervising suitably qualified person certifying that the works have been constructed in accordance with the TasWater approved plans and specifications and that the appropriate level of workmanship has been achieved;
  - b. A request for a joint on-site inspection with TasWater's authorised representative must be made;
  - c. TasWater may, at its discretion, require security for the twelve (12) month defects liability period to the value of 10% of the works must be lodged with TasWater. This security must be in the form of a bank guarantee;
  - d. As constructed drawings must be prepared by a suitably qualified person to TasWater's satisfaction and forwarded to TasWater.
11. After the Certificate of Practical Completion has been issued, a 12 month defects liability period applies to this infrastructure. During this period all defects must be rectified at the developer's cost and to the satisfaction of TasWater. A further 12 month defects liability period may be applied to defects after rectification. TasWater may, at its discretion, undertake rectification of any defects at the developer's cost. Upon completion, of the defects liability period the developer must request TasWater to issue a "Certificate of Final Acceptance". The newly constructed infrastructure will be transferred to TasWater upon issue of this certificate and TasWater will release any security held for the defects liability period.
12. The developer must take all precautions to protect existing TasWater infrastructure. Any damage caused to existing TasWater infrastructure during the construction period must be promptly reported to TasWater and repaired by TasWater at the developer's cost.
13. Ground levels over the TasWater assets and/or easements must not be altered without the written approval of TasWater.

#### **FINAL PLANS, EASEMENTS & ENDORSEMENTS**

14. Prior to the Sealing of the Final Plan of Survey, a Consent to Register a Legal Document must be obtained from TasWater as evidence of compliance with these conditions when application for sealing is made.  
*Advice: Council will refer the Final Plan of Survey to TasWater requesting Consent to Register a Legal Document be issued directly to them on behalf of the applicant.*
15. Pipeline easements, to TasWater's satisfaction, must be created over any existing or proposed TasWater infrastructure and be in accordance with TasWater's standard pipeline easement conditions.

**DEVELOPMENT ASSESSMENT FEES**

16. The applicant or landowner as the case may be, must pay a development assessment and Consent to Register a Legal Document fee to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date they are paid to TasWater, as follows:

- a. \$343.55 for development assessment; and
- b. \$136.58 for Consent to Register a Legal Document

The payment is required within 30 days of the issue of an invoice by TasWater.

**Advice**

**General**

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

**Advice to the Drainage Authority**

The combined system is at capacity in this area. TasWater cannot accept additional flows of stormwater into this area within the combined system over those currently discharged.

The Drainage Authority will be required to either refuse or condition the development to ensure the current service standard of the combined system is not compromised.

**Declaration**

The drawings/documents and conditions stated above constitute TasWater’s Submission to Planning Authority Notice.

**Authorised by**



**Jason Taylor**  
Development Assessment Manager

**TasWater Contact Details**

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au