

## Submission to Planning Authority Notice

Council Planning Permit No.	DA0446/2018	Council notice date	7/08/2018
<b>TasWater details</b>			
TasWater Reference No.	TWDA 2018/01296-LCC	Date of response	19/09/2018
TasWater Contact	David Boyle	Phone No.	6345 6323
<b>Response issued to</b>			
Council name	LAUNCESTON CITY COUNCIL		
Contact details	planning.admin@launceston.tas.gov.au		
<b>Development details</b>			
Address	LINDSAY ST, INVERMAY	Property ID (PID)	3371464
Description of development	Community Meeting & Entertainment - Construction of Automobile Museum		
<b>Schedule of drawings/documents</b>			
	Prepared by	Drawing/document No.	Revision No.
	Rare.	17.360 DA02	C
	Artas	171051 A0001-DA01	DA01
<b>Conditions</b>			
Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater imposes the following conditions on the permit for this application:			
<b>CONNECTIONS, METERING &amp; BACKFLOW</b>			
1. A suitably sized water supply with metered connection / sewerage system and connection for this Automobile Museum development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.			
<b>Advice:</b> TasWater will not accept direct fire boosting from the network unless it can be demonstrated that the periodic testing of the system will not have a significant negative effect on our network and the minimum service requirements of other customers serviced by the network. To this end break tanks may be required with the rate of flow into the break tank controlled so that peak flows to fill the tank do not also cause negative effect on the network.			
2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.			
3. Prior to commencing construction of the development, any water connection utilised for construction must have a backflow prevention device and water meter installed, to the satisfaction of TasWater.			
<b>DEVELOPMENT ASSESSMENT FEES</b>			
4. The applicant or landowner as the case may be, must pay a development assessment fee of \$351,28 to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date paid to TasWater:			
The payment is required within 30 days of the issue of an invoice by TasWater.			

**Advice**

**General**

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

**Advice to the Drainage Authority**


The combined system is at capacity in this area. TasWater cannot accept additional flows of stormwater into this area within the combined system over those currently discharged.

The Drainage Authority will be required to either refuse or condition the development to ensure the current service standard of the combined system is not compromised.

**Declaration**

The drawings/documents and conditions stated above constitute TasWater’s Submission to Planning Authority Notice.

**Authorised by**



**Jason Taylor**  
Development Assessment Manager

**TasWater Contact Details**

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au