

Submission to Planning Authority Notice

Council Planning Permit No.	DA0039/2019	Council notice date	15/02/2019
TasWater details			
TasWater Reference No.	TWDA 2019/00181-LCC	Date of response	27/02/2019
TasWater Contact	David Boyle	Phone No.	6345 6323
Response issued to			
Council name	LAUNCESTON CITY COUNCIL		
Contact details	planning.admin@launceston.tas.gov.au		
Development details			
Address	6 ST GEORGES SQUARE, LAUNCESTON	Property ID (PID)	6609773
Description of development	Demolition and construction of building with cafe		
Schedule of drawings/documents			
	Prepared by	Drawing/document No.	Revision No.
			Date of Issue
Prime Design	Site Plan / PD17273-01	07	9/01/2019
Conditions			
<p>Pursuant to the <i>Water and Sewerage Industry Act 2008</i> (TAS) Section 56P(1) TasWater imposes the following conditions on the permit for this application:</p> <p>CONNECTIONS, METERING & BACKFLOW</p> <ol style="list-style-type: none"> 1. A suitably sized water supply with metered connection / sewerage system and connection for this dwelling/café development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit. 2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost. 3. Prior to commencing construction use of the development, any water connection utilised for construction must have a backflow prevention device and water meter installed, to the satisfaction of TasWater. <p>TRADE WASTE</p> <ol style="list-style-type: none"> 4. Prior to the commencement of operation the developer/property owner must obtain Consent to discharge Trade Waste from TasWater. 5. The developer must install appropriately sized and suitable pre-treatment devices prior to gaining Consent to discharge. 6. The Developer/property owner must comply with all TasWater conditions prescribed in the Trade Waste Consent. <p>DEVELOPMENT ASSESSMENT FEES</p> <ol style="list-style-type: none"> 7. The applicant or landowner as the case may be, must pay a development assessment fee of \$211.63 to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date . paid to TasWater. <p>The payment is required within 30 days of the issue of an invoice by TasWater.</p>			

Advice

General

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

Temporary Cap & Seal

The applicant must engage a registered plumber to temporarily cap and seal internal water (prior to water meter) and sewer (upstream of the inspection opening) connections under demolition works to protect TasWater's infrastructure from contamination.

Trade Waste

Prior to any Building and/or Plumbing work being undertaken, the applicant will need to make an application to TasWater for a Certificate for Certifiable Work (Building and/or Plumbing). The Certificate for Certifiable Work (Building and/or Plumbing) must accompany all documentation submitted to Council. Documentation must include a floor and site plan with:

Location of all pre-treatment devices i.e. Oil Water Separator;

Schematic drawings and specification (including the size and type) of any proposed pre-treatment device and drainage design; and

Location of an accessible sampling point in accordance with the TasWater Trade Waste Flow Meter and Sampling Specifications for sampling discharge.

At the time of submitting the Certificate for Certifiable Work (Building and/or Plumbing) a Trade Waste Application form is also required.

If the nature of the business changes or the business is sold, TasWater is required to be informed in order to review the pre-treatment assessment.

The application forms are available at <http://www.taswater.com.au/Customers/Liquid-Trade-Waste/Commercial>.

Declaration

The drawings/documents and conditions stated above constitute TasWater's Submission to Planning Authority Notice.

Authorised by



Jason Taylor

Development Assessment Manager

TasWater Contact Details

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au