



Submission to Planning Authority Notice

| | | | | |
|---|---|-----------------------------|--------------|---------------|
| Council Planning Permit No. | DA0679/2019 | Council notice date | 3/12/2019 | |
| TasWater details | | | | |
| TasWater Reference No. | TWDA 2019/01789-LCC | Date of response | 6/12/2019 | |
| TasWater Contact | David Boyle | Phone No. | 6345 6323 | |
| Response issued to | | | | |
| Council name | LAUNCESTON CITY COUNCIL | | | |
| Contact details | planning.admin@launceston.tas.gov.au | | | |
| Development details | | | | |
| Address | 90-110 WILLIS ST, LAUNCESTON | Property ID (PID) | 3084836 | |
| Description of development | Subdivision and construction of a multi-storey car park | | | |
| Schedule of drawings/documents | | | | |
| | Prepared by | Drawing/document No. | Revision No. | Date of Issue |
| | Artas Architects | 191013 A7000-DA06 | DA06 | 16/08/2019 |
| | PDA Surveyors | Subdivision Plan/43682J-P04 | | 19/06/2019 |
| | PDA Surveyors | Subdivision Plan/43682J-P05 | | 22/07/2019 |
| Conditions | | | | |
| <p>Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater imposes the following conditions on the permit for this application:</p> <p>CONNECTIONS, METERING & BACKFLOW</p> <ol style="list-style-type: none"> 1. A suitably sized water supply with metered connections / sewerage system and connections to each lot of the development, and a suitably sized water supply with metered connection / sewerage system and connections for the multi-storey car park must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit. 2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost. 3. Prior to commencing construction of the subdivision, any water connection utilised for construction must have a backflow prevention device and water meter installed, to the satisfaction of TasWater. <p>FINAL PLANS, EASEMENTS & ENDORSEMENTS</p> <ol style="list-style-type: none"> 4. Prior to the Sealing of the Final Plan of Survey, a Consent to Register a Legal Document must be obtained from TasWater as evidence of compliance with these conditions when application for sealing is made. <i>Advice: Council will refer the Final Plan of Survey to TasWater requesting Consent to Register a Legal Document be issued directly to them on behalf of the applicant.</i> <p>DEVELOPMENT ASSESSMENT FEES</p> <ol style="list-style-type: none"> 5. The applicant or landowner as the case may be, must pay a development assessment and Consent to Register a Legal Document fee to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date they are paid to TasWater, as follows: <ol style="list-style-type: none"> a. \$351.28 for development assessment; and | | | | |

b. \$149.20 for Consent to Register a Legal Document

The payment is required by the due date as noted on the statement when issued by TasWater.

6. In the event Council approves a staging plan, a Consent to Register a Legal Document fee for each stage, must be paid commensurate with the number of Equivalent Tenements in each stage, as approved by Council.

Advice

General

For information on TasWater development standards, please visit

<https://www.taswater.com.au/Development/Technical-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

Declaration

The drawings/documents and conditions stated above constitute TasWater’s Submission to Planning Authority Notice.

Authorised by



Jason Taylor

Development Assessment Manager

TasWater Contact Details

| | | | |
|-------|------------------------------|-----|---------------------|
| Email | development@taswater.com.au | Web | www.taswater.com.au |
| Mail | GPO Box 1393 Hobart TAS 7001 | | |