

## Submission to Planning Authority Notice

Council Planning Permit No.	DA0672/2019	Council notice date	4/12/2019
<b>TasWater details</b>			
TasWater Reference No.	TWDA 2019/01790-LCC	Date of response	19/06/2020
TasWater Contact	Sam Bryant	Phone No.	(03) 6237 8642
<b>Response issued to</b>			
Council name	LAUNCESTON CITY COUNCIL		
Contact details	planning.admin@launceston.tas.gov.au		
<b>Development details</b>			
Address	59-61 FREDERICK ST, LAUNCESTON	Property ID (PID)	6676853
Description of development	Multiple dwellings x 2		
<b>Schedule of drawings/documents</b>			
	Prepared by	Drawing/document No.	Revision No.
	Lez Penzes Architect	Site Plan	--
			Date of Issue
			July 2019
<b>Conditions</b>			
<b>SUBMISSION TO PLANNING AUTHORITY NOTICE OF PLANNING APPLICATION REFERRAL</b>			
Pursuant to the <i>Water and Sewerage Industry Act 2008</i> (TAS) Section 56P(1) TasWater imposes the following conditions on the permit for this application:			
<b>CONNECTIONS, METERING &amp; BACKFLOW</b>			
1. A suitably sized water supply with metered connections and sewerage system and connections to the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.			
2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.			
<b>56W CONSENT</b>			
3. Prior to the issue of the Certificate for Certifiable Work (Building) and/or (Plumbing) by TasWater the applicant or landowner as the case may be must make application to TasWater pursuant to section 56W of the <i>Water and Sewerage Industry Act 2008</i> for its consent in respect of that part of the development which is built within a TasWater easement or over or within two metres of TasWater infrastructure.			
<b>DEVELOPMENT ASSESSMENT FEES</b>			
4. The applicant or landowner as the case may be, must pay a development assessment fee of \$351.28, and a Consent to Register a Legal Document fee of \$149.20 to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date paid to TasWater.			
The payment is required within 30 days of the issue of an invoice by TasWater.			

## Advice

### General

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

### Service Locations

Please note that the developer is responsible for arranging to locate the existing TasWater infrastructure and clearly showing it on the drawings. Existing TasWater infrastructure may be located by a surveyor and/or a private contractor engaged at the developers cost to locate the infrastructure.

A copy of the GIS is included in email with this notice and should aid in updating of the documentation.

The location of this infrastructure as shown on the GIS is indicative only.

- (a) A permit is required to work within TasWater's easements or in the vicinity of its infrastructure. Further information can be obtained from TasWater
- (b) TasWater has listed a number of service providers who can provide asset detection and location services should you require it. Visit [www.taswater.com.au/Development/Service-location](http://www.taswater.com.au/Development/Service-location) for a list of companies
- (c) TasWater will locate residential water stop taps free of charge
- (d) Sewer drainage plans or Inspection Openings (IO) for residential properties are available from your local council.

### 56W Consent

The plans submitted with the application for the Certificate for Certifiable Work (Building) and/or (Plumbing) will need to show footings of proposed buildings located over or within 2.0m from TasWater pipes and will need to be designed by a suitably qualified person to adequately protect the integrity of TasWater's infrastructure, and to TasWater's satisfaction, be in accordance with AS3500 Part 2.2 Section 3.8 to ensure that no loads are transferred to TasWater's pipes. These plans will need to also include a cross sectional view through the footings which clearly shows;

- (e) Existing pipe depth and proposed finished surface levels over the pipe;
- (f) The line of influence from the base of the footing must pass below the invert of the pipe and be clear of the pipe trench and;
- (g) A note on the plan indicating how the pipe location and depth were ascertained.

## Declaration

The drawings/documents and conditions stated above constitute TasWater's Submission to Planning Authority Notice.

### Authorised by



**Jason Taylor**

Development Assessment Manager

## TasWater Contact Details

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au