

Submission to Planning Authority Notice

Council Planning Permit No.	DA0724/2020	Council notice date	20/10/2020
TasWater details			
TasWater Reference No.	TWDA 2020/01722-LCC	Date of response	29/01/2021
TasWater Contact	David Boyle	Phone No.	0436 629 652
Response issued to			
Council name	CITY OF LAUNCESTON		
Contact details	PlanningAdmin@launceston.tas.gov.au		
Development details			
Address	30 KERRY CRT, SUMMERHILL	Property ID (PID)	6645280
Description of development	Multiple dwellings x 2 (1 ex + 1 new) + garage		
Schedule of drawings/documents			
Prepared by	Drawing/document No.	Revision No.	Date of Issue
Edwards + Simpson	20019/A113Concept Hydraulics	P3	27/01/2021
Conditions			
<p>Pursuant to the <i>Water and Sewerage Industry Act 2008</i> (TAS) Section 56P(1) TasWater imposes the following conditions on the permit for this application:</p> <p>CONNECTIONS, METERING & BACKFLOW</p> <ol style="list-style-type: none"> 1. A suitably sized water supply with metered connection and sewerage system and connection 2 unit development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit. 2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost. 3. Prior to use of the development, any water connection utilised for construction/the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater. 4. Prior to applying for a TasWater Certificate of Certifiable Works (CCW) to commence building and plumbing work for this development, the City of Launceston must have installed the proposed new public stormwater main to remove the stormwater from TasWater's sewer main. <p>DEVELOPMENT ASSESSMENT FEES</p> <ol style="list-style-type: none"> 5. The applicant or landowner as the case may be, must pay a development assessment fee of \$211.63 to TasWater, as approved by the Economic Regulator and the fee will be indexed, until the date paid to TasWater. <p>The payment is required within 30 days of the issue of an invoice by TasWater.</p>			

Advice

General

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

Service Locations

Please note that the developer is responsible for arranging to locate the existing TasWater infrastructure and clearly showing it on the drawings. Existing TasWater infrastructure may be located by a surveyor and/or a private contractor engaged at the developers cost to locate the infrastructure.

A copy of the GIS is included in email with this notice and should aid in updating of the documentation.

The location of this infrastructure as shown on the GIS is indicative only.

- (a) A permit is required to work within TasWater's easements or in the vicinity of its infrastructure. Further information can be obtained from TasWater
- (b) TasWater has listed a number of service providers who can provide asset detection and location services should you require it. Visit www.taswater.com.au/Development/Service-location for a list of companies
- (c) TasWater will locate residential water stop taps free of charge
- (d) Sewer drainage plans or Inspection Openings (IO) for residential properties are available from your local council.

Metering Vacant Lot

TasWater records indicate this property does not have a water meter installed on the connection to the TasWater water supply.

Prior to obtaining Building/Plumbing Approvals from council, the owner should make application to TasWater for the supply & installation of a water meter. TasWater will proceed to install a water meter on the water connection and forward an invoice for \$266.72.

NOTE: In accordance with the WATER AND SEWERAGE INDUSTRY ACT 2008 - SECT 56ZB A regulated entity may charge a person for the reasonable cost of –

- (a) a meter; and
- (b) installing a meter.

56W Consent

The plans submitted with the application for the Certificate for Certifiable Work (Building) and/or (Plumbing) will need to show footings of proposed buildings located over or within 2.0m from TasWater pipes and will need to be designed by a suitably qualified person to adequately protect the integrity of TasWater's infrastructure, and to TasWater's satisfaction, be in accordance with AS3500 Part 2.2 Section 3.8 to ensure that no loads are transferred to TasWater's pipes. These plans will need to also include a cross sectional view through the footings which clearly shows;

- (a) Existing pipe depth and proposed finished surface levels over the pipe;
- (b) The line of influence from the base of the footing must pass below the invert of the pipe and be clear of the pipe trench and;
- (c) A note on the plan indicating how the pipe location and depth were ascertained.

Boundary Trap Area

The proposed development is within a boundary trap area and the developer will need to provide a boundary trap that prevents noxious gases or persistent odours back venting into the property's sanitary

drain. The boundary trap is to be contained within the property boundaries and the property owner remains responsible for the ownership, operation and maintenance of the boundary trap.

Advice to Planning Authority (Council) and developer on fire coverage

TasWater cannot provide a supply of water for the purposes of firefighting to the lots on the plan.

Advice to the Drainage Authority

The combined system is at capacity in this area. TasWater cannot accept additional flows of stormwater into this area within the combined system over those currently discharged.

The Drainage Authority will be required to either refuse or condition the development to ensure the current service standard of the combined system is not compromised.

TasWater have a small number of townships that are on Boil Water and Do Not Consume Alerts. Please visit <http://www.taswater.com.au/News/Outages---Alerts> for a current list of these areas.

Declaration

The drawings/documents and conditions stated above constitute TasWater’s Submission to Planning Authority Notice.

Authorised by



Jason Taylor

Development Assessment Manager

TasWater Contact Details

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au