



Submission to Planning Authority Notice

Council Planning Permit No.	DA0180/2021	Council notice date	13/04/2021
TasWater details			
TasWater Reference No.	TWDA 2021/00554-LCC	Date of response	20/04/2021
TasWater Contact	Phil Papps	Phone No.	0474 931 272
Response issued to			
Council name	CITY OF LAUNCESTON		
Contact details	PlanningAdmin@launceston.tas.gov.au		
Development details			
Address	29 CONNAUGHT CRES , WEST LAUNCESTON	Property ID (PID)	6637010
Description of development	Multiple dwellings x 3 (2 new + 1 ex)		
Schedule of drawings/documents			
	Prepared by	Drawing/document No.	Revision No.
	S Group Architects	Site Plan / A1-002	1
			Date of Issue
			13/04/2021
Conditions			
Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater imposes the following conditions on the permit for this application:			
CONNECTIONS, METERING & BACKFLOW			
1. A suitably sized water supply with metered connections and sewerage system and connections to each lot of the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.			
2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.			
3. Prior to use of the development, any water connection utilised for the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater.			
DEVELOPMENT ASSESSMENT FEES			
4. The applicant or landowner as the case may be, must pay a development assessment fee of \$351.28 to TasWater, as approved by the Economic Regulator and the fee will be indexed, until the date paid to TasWater.			
The payment is required within 30 days of the issue of an invoice by TasWater.			
Advice			
General			
For information on TasWater development standards, please visit http://www.taswater.com.au/Development/Development-Standards			
For application forms please visit http://www.taswater.com.au/Development/Forms			
Service Locations			
Please note that the developer is responsible for arranging to locate the existing TasWater infrastructure and clearly showing it on the drawings. Existing TasWater infrastructure may be located by a surveyor			

and/or a private contractor engaged at the developers cost to locate the infrastructure.

The location of this infrastructure as shown on the GIS is indicative only.

- (a) A permit is required to work within TasWater’s easements or in the vicinity of its infrastructure. Further information can be obtained from TasWater
- (b) TasWater has listed a number of service providers who can provide asset detection and location services should you require it. Visit www.taswater.com.au/Development/Service-location for a list of companies
- (c) TasWater will locate residential water stop taps free of charge
- (d) Sewer drainage plans or Inspection Openings (IO) for residential properties are available from your local council.

Advice to the Drainage Authority

The combined system is at capacity in this area. TasWater cannot accept additional flows of stormwater into this area within the combined system over those currently discharged.

The Drainage Authority will be required to either refuse or condition the development to ensure the current service standard of the combined system is not compromised.

Declaration

The drawings/documents and conditions stated above constitute TasWater’s Submission to Planning Authority Notice.

Authorised by



Jason Taylor
Development Assessment Manager

TasWater Contact Details

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au