

## Amended Submission to Planning Authority Notice

Council Planning Permit No.	DA0853/2020	Council notice date	22/12/2020
<b>TasWater details</b>			
TasWater Reference No.	TWDA 2020/02203-LCC	Date of response	11/02/2021
		Amended Response	25/02/2021
TasWater Contact	Jake Walley	Phone No.	0467 625 805
<b>Response issued to</b>			
Council name	CITY OF LAUNCESTON		
Contact details	PlanningAdmin@launceston.tas.gov.au		
<b>Development details</b>			
Address	34 GALVIN ST, SOUTH LAUNCESTON	Property ID (PID)	6617036
Description of development	Multiple Dwellings x2		
<b>Schedule of drawings/documents</b>			
	Prepared by	Drawing/document No.	Revision No.
		Date of Issue	
Design To Live	External Services GLVN34	R3	08/01/2021
<b>Conditions</b>			
Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater imposes the following conditions on the permit for this application:			
<b>CONNECTIONS, METERING &amp; BACKFLOW</b>			
<ol style="list-style-type: none"> <li>1. A suitably sized water supply with metered connection and sewerage system and connection to the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit.</li> <li>2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost.</li> <li>3. Prior to commencing construction/use of the development, any water connection utilised for construction/the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater.</li> </ol>			
<b>ASSET CREATION &amp; INFRASTRUCTURE WORKS</b>			
<ol style="list-style-type: none"> <li>4. Plans submitted with the application for Certificate(s) for Certifiable Work (Building and/or Plumbing) / Engineering Design Approval must, to the satisfaction of TasWater show, all existing, redundant and/or proposed property services and mains.</li> <li>5. Prior to applying for a Permit to Construct new infrastructure the developer must obtain from TasWater Engineering Design Approval for new TasWater infrastructure. The application for Engineering Design Approval must include engineering design plans prepared by a suitably qualified person showing the hydraulic servicing requirements for water to TasWater's satisfaction.</li> <li>6. Prior to works commencing, a Permit to Construct must be applied for and issued by TasWater. All infrastructure works must be inspected by TasWater and be to TasWater's satisfaction.</li> <li>7. In addition to any other conditions in this permit, all works must be constructed under the supervision of a suitably qualified person in accordance with TasWater's requirements.</li> </ol>			

8. Prior to the issue of a Certificate of Water and sewerage Compliance (Building and/or Plumbing) all additions, extensions, alterations or upgrades to TasWater's water and sewerage infrastructure required to service the development, generally as shown on the concept servicing plan "Design to Live, External Services GLVN34, 5/9, rev R3 dated 08/01/2021", are to be constructed at the expense of the developer to the satisfaction of TasWater, with live connections performed by TasWater.
9. After testing/disinfection, to TasWater's requirements, of newly created works, the developer must apply to TasWater for connection of these works to existing TasWater infrastructure, at the developer's cost.
10. At practical completion of the water and sewerage works and prior to applying to TasWater for a Certificate of Water and Sewerage Compliance (Building and/or Plumbing), the developer must obtain a Certificate of Practical Completion from TasWater for the works that will be transferred to TasWater. To obtain a Certificate of Practical Completion:
  - a. Written confirmation from the supervising suitably qualified person certifying that the works have been constructed in accordance with the TasWater approved plans and specifications and that the appropriate level of workmanship has been achieved;
  - b. A request for a joint on-site inspection with TasWater's authorised representative must be made;
  - c. Security for the twelve (12) month defects liability period to the value of 10% of the works must be lodged with TasWater. This security must be in the form of a bank guarantee;
  - d. Work As Constructed drawings and documentation must be prepared by a suitably qualified person to TasWater's satisfaction and forwarded to TasWater.
11. After the Certificate of Practical Completion has been issued, a 12 month defects liability period applies to this infrastructure. During this period all defects must be rectified at the developer's cost and to the satisfaction of TasWater. A further 12 month defects liability period may be applied to defects after rectification. TasWater may, at its discretion, undertake rectification of any defects at the developer's cost. Upon completion, of the defects liability period the developer must request TasWater to issue a "Certificate of Final Acceptance". The newly constructed infrastructure will be transferred to TasWater upon issue of this certificate and TasWater will release any security held for the defects liability period.
12. The developer must take all precautions to protect existing TasWater infrastructure. Any damage caused to existing TasWater infrastructure during the construction period must be promptly reported to TasWater and repaired by TasWater at the developer's cost.
13. Ground levels over the TasWater assets and/or easements must not be altered without the written approval of TasWater.
14. A construction management plan must be submitted with the application for TasWater Engineering Design Approval. The construction management plan must detail how the new TasWater infrastructure will be constructed while maintaining current levels of services provided by TasWater to the community. The construction plan must also include a risk assessment and contingency plans covering major risks to TasWater during any works. The construction plan must be to the satisfaction of TasWater prior to TasWater's Engineering Design Approval being issued.

## DEVELOPMENT ASSESSMENT FEES

15. The applicant or landowner as the case may be, must pay a development assessment fee of \$211.63 to TasWater, as approved by the Economic Regulator and the fee will be indexed, until the date paid to TasWater.

The payment is required within 30 days of the issue of an invoice by TasWater.

## Advice

### General

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

### Service Locations

Please note that the developer is responsible for arranging to locate the existing TasWater infrastructure and clearly showing it on the drawings. Existing TasWater infrastructure may be located by a surveyor and/or a private contractor engaged at the developers cost to locate the infrastructure.

- (a) A permit is required to work within TasWater's easements or in the vicinity of its infrastructure. Further information can be obtained from TasWater
- (b) TasWater has listed a number of service providers who can provide asset detection and location services should you require it. Visit [www.taswater.com.au/Development/Service-location](http://www.taswater.com.au/Development/Service-location) for a list of companies
- (c) TasWater will locate residential water stop taps free of charge
- (d) Sewer drainage plans or Inspection Openings (IO) for residential properties are available from your local council.

### Boundary Trap Area

The proposed development is within a boundary trap area and the developer will need to provide a boundary trap that prevents noxious gases or persistent odours back venting into the property's sanitary drain. The boundary trap is to be contained within the property boundaries and the property owner remains responsible for the ownership, operation and maintenance of the boundary trap.

### Advice to the Drainage Authority

The combined system is at capacity in this area. TasWater cannot accept additional flows of stormwater into this area within the combined system over those currently discharged.

The Drainage Authority will be required to either refuse or condition the development to ensure the current service standard of the combined system is not compromised.

## Declaration

The drawings/documents and conditions stated above constitute TasWater's Submission to Planning Authority Notice.

### Authorised by



**Jason Taylor**  
Development Assessment Manager

TasWater Contact Details			
Phone	13 6992	Email	<a href="mailto:development@taswater.com.au">development@taswater.com.au</a>
Mail	GPO Box 1393 Hobart TAS 7001	Web	<a href="http://www.taswater.com.au">www.taswater.com.au</a>