

Submission to Planning Authority Notice

| | | | |
|--|--|-----------------------------|----------------------|
| Council Planning Permit No. | DA0439/2022 | Council notice date | 29/07/2022 |
| TasWater details | | | |
| TasWater Reference No. | TWDA 2022/01229-LCC | Date of response | 14/12/2022 |
| TasWater Contact | David Boyle | Phone No. | 0436 629 652 |
| Response issued to | | | |
| Council name | CITY OF LAUNCESTON | | |
| Contact details | Planning.Admin@launceston.tas.gov.au | | |
| Development details | | | |
| Address | 5 ROSE LANE, SOUTH LAUNCESTON | Property ID (PID) | 3329661 |
| Description of development | Section 40T rezoning and development (six buildings) | | |
| Schedule of drawings/documents | | | |
| | Prepared by | Drawing/document No. | Revision No. |
| | AD Design + Consulting | D-01-07-01 | B |
| | AD Design + Consulting | D-01-10-01 | B |
| | | | Date of Issue |
| | | | 26/09/2022 |
| | | | 16/09/2022 |
| Conditions | | | |
| <p>Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater makes the following submission(s):</p> <ol style="list-style-type: none"> TasWater does not object to the draft amendment to planning scheme and has no formal comments for the Tasmanian Planning Commission in relation to this matter and does not require to be notified of nor attend any subsequent hearings. <p>Pursuant to the <i>Water and Sewerage Industry Act 2008 (TAS)</i> Section 56P(1) TasWater imposes the following conditions on the permit for this application:</p> <p>CONNECTIONS, METERING & BACKFLOW</p> <ol style="list-style-type: none"> A suitably sized water supply with metered connections and sewerage system and connections to each lot of the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost. Prior to use of the development, any water connection utilised for construction/the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater. <p>ASSET CREATION & INFRASTRUCTURE WORKS</p> <ol style="list-style-type: none"> Plans submitted with the application for Engineering Design Approval must, to the satisfaction of TasWater show, all existing, redundant and/or proposed property services and mains. Prior to applying for a Permit to Construct to construct new infrastructure the developer must obtain from TasWater Engineering Design Approval for new TasWater infrastructure. The application for Engineering Design Approval must include engineering design plans prepared by a suitably qualified person showing the hydraulic servicing requirements for sewerage to TasWater's satisfaction. | | | |

6. Prior to works commencing, a Permit to Construct must be applied for and issued by TasWater. All infrastructure works must be inspected by TasWater and be to TasWater's satisfaction.
7. In addition to any other conditions in this permit, all works must be constructed under the supervision of a suitably qualified person in accordance with TasWater's requirements.
8. Prior to the issue of a Consent to Register a Legal Document / Certificate of Water and sewerage Compliance (Building and/or Plumbing) all additions, extensions, alterations or upgrades to TasWater's water and sewerage infrastructure required to service the development, are to be completed generally as shown on, and in accordance with, the plans listed in the schedule of drawings/documents, and are to be constructed at the expense of the developer to the satisfaction of TasWater, with live connections performed by TasWater.
9. After testing, to TasWater's requirements, of newly created works, the developer must apply to TasWater for connection of these works to existing TasWater infrastructure, at the developer's cost.
10. At practical completion of the water and sewerage works and prior to TasWater issuing a Consent to a Register Legal Document / applying to TasWater for a Certificate of Water and Sewerage Compliance (Building and/or Plumbing), the developer must obtain a Certificate of Practical Completion from TasWater for the works that will be transferred to TasWater. To obtain a Certificate of Practical Completion:
 - a. Written confirmation from the supervising suitably qualified person certifying that the works have been constructed in accordance with the TasWater approved plans and specifications and that the appropriate level of workmanship has been achieved.
 - b. A request for a joint on-site inspection with TasWater's authorised representative must be made.
 - c. Security for the twelve (12) month defects liability period to the value of 10% of the works must be lodged with TasWater. This security must be in the form of a bank guarantee.
 - d. Work As Constructed drawings and documentation must be prepared by a suitably qualified person to TasWater's satisfaction and forwarded to TasWater.

Upon TasWater issuing a Certificate of Practical Completion, the newly constructed infrastructure is deemed to have transferred to TasWater.

11. After the Certificate of Practical Completion has been issued, a 12-month defects liability period applies to this infrastructure. During this period all defects must be rectified at the developer's cost and to the satisfaction of TasWater. A further 12-month defects liability period may be applied to defects after rectification. TasWater may, at its discretion, undertake rectification of any defects at the developer's cost. Upon completion, of the defects liability period the developer must request TasWater to issue a "Certificate of Final Acceptance". TasWater will release any security held for the defect's liability period.
12. The developer must take all precautions to protect existing TasWater infrastructure. Any damage caused to existing TasWater infrastructure during the construction period must be promptly reported to TasWater and repaired by TasWater at the developer's cost.
13. Ground levels over the TasWater assets and/or easements must not be altered without the written approval of TasWater.

TRADE WASTE

14. Prior to the commencement of operation, the developer/property owner must obtain Consent to discharge Trade Waste from TasWater.
15. The developer must install appropriately sized and suitable pre-treatment devices prior to gaining

Consent to discharge.

16. The Developer/property owner must comply with all TasWater conditions prescribed in the Trade Waste Consent

FINAL PLANS, EASEMENTS & ENDORSEMENTS

17. Prior to the Sealing of the Final Plan of Survey, a Consent to Register a Legal Document must be obtained from TasWater as evidence of compliance with these conditions when application for sealing is made.

Advice: Council will refer the Final Plan of Survey to TasWater requesting Consent to Register a Legal Document be issued directly to them on behalf of the applicant.

DEVELOPMENT ASSESSMENT FEES

18. The applicant or landowner as the case may be, must pay a development assessment fee of \$723.84 and a Consent to Register a Legal Document fee of \$239.90 to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date paid to TasWater.

The payment is required within 30 days of the issue of an invoice by TasWater.

Advice

Water Submetering

As of July 1, 2022, TasWater's Sub-Metering Policy no longer permits TasWater sub-meters to be installed for new developments. Please ensure plans submitted with the application for Certificate(s) for Certifiable Work (Building and/or Plumbing) reflect this. For clarity, TasWater does not object to private sub-metering arrangements. Further information is available on our website (www.taswater.com.au) within our Sub-Metering Policy and Water Metering Guidelines.

General

For information on TasWater development standards, please visit <https://www.taswater.com.au/building-and-development/technical-standards>

For application forms please visit <https://www.taswater.com.au/building-and-development/development-application-form>

Boundary Trap Area

The proposed development is within a boundary trap area and the developer will need to provide a boundary trap that prevents noxious gases or persistent odours back venting into the property's sanitary drain. The boundary trap is to be contained within the property boundaries and the property owner remains responsible for the ownership, operation and maintenance of the boundary trap.

Advice to the Drainage Authority

The combined system is at capacity in this area. TasWater cannot accept additional flows of stormwater into this area within the combined system over those currently discharged.

The Drainage Authority will be required to either refuse or condition the development to ensure the current service standard of the combined system is not compromised.

Trade Waste

Prior to any Building and/or Plumbing work being undertaken, the applicant will require a Certificate for Certifiable Work (Building and/or Plumbing). The Certificate for Certifiable Work (Building and/or Plumbing) must accompany all documentation submitted to Council. Documentation must include a floor and site plan with:

Location of all pre-treatment devices

Schematic drawings and specification (including the size and type) of any proposed pre-treatment device and drainage design; and

Location of an accessible sampling point in accordance with the TasWater Trade Waste Flow Meter and Sampling Specifications for sampling discharge.

At the time of submitting the application for a Certificate for Certifiable Work (Building and/or Plumbing) a Trade Waste Application is required.

The application forms are available at <http://www.taswater.com.au/Customers/Liquid-Trade-Waste/Commercial>.

Declaration

The drawings/documents and conditions stated above constitute TasWater’s Submission to Planning Authority Notice.

TasWater Contact Details

| | | | |
|-------|------------------------------|-------|-----------------------------|
| Phone | 13 6992 | Email | development@taswater.com.au |
| Mail | GPO Box 1393 Hobart TAS 7001 | Web | www.taswater.com.au |