

Submission to Planning Authority Notice

Council Planning Permit No.	DA0048/2018	Council notice date	08/02/2018
TasWater details			
TasWater Reference No.	TWDA 2018/00172-LCC	Date of response	07/03/2018
TasWater Contact	Amanda Craig	Phone No.	03) 6345 6318
Response issued to			
Council name	LAUNCESTON CITY COUNCIL		
Contact details	planning.admin@launceston.tas.gov.au		
Development details			
Address	341-349 HOBART ROAD, YOUNGTOWN	Property ID (PID)	2831027
Description of development	2 lot subdivision		
Schedule of drawings/documents			
Prepared by	Drawing/document No.	Revision No.	Date of Issue
D J McCulloch Surveying	0618-03DA Services & Easement Plan	--	28/02/2018
Dallas McCulloch	Email correspondence to Carolyn Wrangmore and Luke Rogers	--	28/02/2018
Conditions			
<p>Pursuant to the <i>Water and Sewerage Industry Act 2008</i> (TAS) Section 56P(1) TasWater imposes the following conditions on the permit for this application:</p> <p>CONNECTIONS, METERING & BACKFLOW</p> <ol style="list-style-type: none"> 1. A suitably sized water supply with metered connection / sewerage system and connection to each lot of the development must be designed and constructed to TasWater's satisfaction and be in accordance with any other conditions in this permit. 2. Any removal/supply and installation of water meters and/or the removal of redundant and/or installation of new and modified property service connections must be carried out by TasWater at the developer's cost. 3. Prior to commencing construction of the subdivision/use of the development, any water connection utilised for construction/the development must have a backflow prevention device and water meter installed, to the satisfaction of TasWater. <p>Where the development activity is unknown for new industrial and commercial lots, the boundary backflow containment hazard rating for that lot shall default to High.</p> <p><i>Advice: Refer to TasWater's Boundary Backflow Containment Selection Requirements for Guidance.</i></p> <p>FINAL PLANS, EASEMENTS & ENDORSEMENTS</p> <ol style="list-style-type: none"> 4. Prior to the Sealing of the Final Plan of Survey, a Consent to Register a Legal Document must be obtained from TasWater and the certificate must be submitted to the Council as evidence of compliance with these conditions when application for sealing is made. 5. Pipeline easements, to TasWater's satisfaction, must be created over any existing or proposed TasWater infrastructure and be in accordance with TasWater's standard pipeline easement conditions. 			

DEVELOPMENT ASSESSMENT FEES

6. The applicant or landowner as the case may be, must pay a development assessment and Consent to Register a Legal Document fee to TasWater, as approved by the Economic Regulator and the fees will be indexed, until the date they are paid to TasWater, as follows:

- a. \$252.15 for development assessment; and
- b. \$136.58 for Consent to Register a Legal Document

The payment is required within 30 days of the issue of an invoice by TasWater.

Advice

General

For information on TasWater development standards, please visit <http://www.taswater.com.au/Development/Development-Standards>

For application forms please visit <http://www.taswater.com.au/Development/Forms>

Service Locations

Please note that the developer is responsible for arranging to locate the existing TasWater infrastructure and clearly showing it on the drawings. Existing TasWater infrastructure may be located by a surveyor and/or a private contractor engaged at the developers cost to locate the infrastructure.

A copy of the GIS is included in email with this notice and should aid in updating of the documentation.

The location of this infrastructure as shown on the GIS is indicative only.

- A permit is required to work within TasWater's easements or in the vicinity of its infrastructure. Further information can be obtained from TasWater
- TasWater has listed a number of service providers who can provide asset detection and location services should you require it. Visit www.taswater.com.au/Development/Service-location for a list of companies
- TasWater will locate residential water stop taps free of charge
- Sewer drainage plans or Inspection Openings (IO) for residential properties are available from your local council.

Advice to Planning Authority (Council) and developer on fire coverage

TasWater cannot provide a supply of water for the purposes of firefighting to the lots on the plan.

Declaration

The drawings/documents and conditions stated above constitute TasWater's Submission to Planning Authority Notice.

Authorised by



Jason Taylor

Development Assessment Manager

TasWater Contact Details

Phone	13 6992	Email	development@taswater.com.au
Mail	GPO Box 1393 Hobart TAS 7001	Web	www.taswater.com.au